

Government of Bihar
Public Health Engineering Department

DISTRIC -SAMASTIPUR

SUB DIVISION -ROSERA

MONTH -MAY 2022

Sl. NO	BLOCK	Panchayat	Location	Parameters									Remarks
				PH	EC	TDS	TH	Cl	Fe	Alka	SO4	F	
1	HASANPUR	PATSA	P.C HIGH SCHOOL PATSA ROW WATER	7.6	590	384	140	28	0.6	156	12	0.7	SAFE
2	HASANPUR	PATSA	P.C HIGH SCHOOL PATSA TRITEAD WATER	7.4	169	111	48	12	0.2	60	4	0.3	SAFE
Desirable Limit				6.5-8.5		500	200	250	1	45	200	1	
permissible Limit * in absence of alternative source				NR		2000	600	1000	NR	NR	400	1.5	

Vined ch
21/5/22
SUB DIVISION CHEMIST

W. S. J.
26/05/22
SUB DIVISION ROSERA

S. J. S.
26/5/22
JE (Hascopy)

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITIONCERTIFICATE

No.136.....

Date : 26-05-2022...

It is certified that an inspection team headed by ...Mr. Asif Jahan.....
 ...S.D.O. (PHED, ROSERA)..... (Name of Officers with
 designation) from ...Public Health, Sub Div. - ROSERA..... (Name of
 Department/Office) inspected the ...P.C. High School, Patra,
Block - Hasanpur Dist - Samastipur..... (Name & Address of the
 School) on ..15-05-2022 and found that the ...P.C. High School,
Patra, Hasanpur Dist - Samastipur..... (Name of School) has safe drinking
 water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.....

Signature with Seal :

Name :

Designation :

26/05/2022
AE, ROSERA
Mr. Asif Jahan
S.D.O.
PH, sub Div
ROSER

S.D.O.
PH, Sub Division, ROSERA

To,

P.C. High School,
at - Patra, P.O - Patra
P.S - Hasanpur, Samastipur
 (Name & Address of the Institution)